REFERENCE NOTES: (X)

1. SPRINKLER RISER UP TO UNITS ABOVE.
2. STANDPIPE UP.
3. 2½" FROM STANDPIPE CONNECT TO 2½" FIRE HOSE VALVE LOCATED WITHIN RECESSED FIRE HOSE VALVE CABINET.
4. STANDPIPE ISOLATION SHUT–OFF VALVE WITH VALVE TAMPER SWITCH.
5. FIRE SPRINKLER RISER, SEE DETAIL.
6. FIRE PROTECTION SUPPLY PIPING LOCATED BELOW GRADE, FOR CONTINUATION SEE CIVIL SITE UTILITY PLANS.
7. SPRINKLER PIPING TO SPRINKLER COVERAGE FOR GARAGES.
8. FLOOR CONTROL VALVE ASSEMBLY, SEE DETAIL.
9. FREEZE PROTECT PIPING TO MAINTAIN 40° DEG. F.

ADAM J BARNEY
LICENSE
No. 69124
STATE OF FLORIDA
PROFESSIONAL ENGINEER

Adam Barney
Jan 17 2018 2:55 PM
CoSign

H1 BUILDING TYPE 1 - GROUND LEVEL - FIRE PROTECTION
1/8" = 1'-0"

PERMIT REVIEW STAMP

ISSUE HISTORY

No.	Date	Description
1	1/18/2018	ISSUE FOR PERMIT

REVISION HISTORY

No.	Date	Description

© 2014 Trade Secrets and Other Confidential Information of FUGLEBERG KOCH, P.L.C. - v.A2013.03.1 and are issued only for the specific project noted on these drawings. Any reproductions, revisions, or modifications of these documents without the expressed written consent of Fugleberg Koch, P.L.C. is prohibited by law.

FUGLEBERG KOCH
2555 Temple Trail, Winter Park, FL 32789 (407) 629-0595
www.fuglebergkoch.com BR569

CONSULTANT
Joseph, Lawrence & Co
Consulting Engineers
1180 HARWOOD AVE. SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL. 321.972.4466
WWW.JLCENG.COM
CA NO. 28730

JLC 17.0137.00

Adam Joseph Barney
P.E. #:69124

SUMMER BAY APTS. II
LAKE COUNTY, FL

Drawn:	MJR/KCM
Checked:	BLS/AJB
Approval:	BLS/AJB
Date:	11/10/2017
Project #:	5389

BUILDING TYPE 1 - GROUND FLOOR PLAN - FIRE PROT.

FP2.01