8 NTS CARBON MONOZIDE ALARM WITH FAN RELAY DETAIL

7 NTS TYPICAL WALL JACK DETAIL (GARAGES)

6 NTS TYPICAL WALL JACK DETAIL (UNITS)

NOTES :

1. CONDENSATE DRAIN SHALL BE PIPED FULL SIZE OF UNIT CONNECTION.
2. CONDENSATE PANS SHALL BE INSTALLED WITH ADEQUATE PITCH TO ENSURE POSITIVE DRAINAGE OF ACCUMILATED CONDENSATE.
3. TRAP CONDENSATE AND DISCHARGE PER PLAN.

4 NTS CONDENSATE DRAIN DETAIL

NOTES:

1. TYPICAL FOR: LOW PRESSURE AND HIGH PRESSURE CONNECTION TO MAIN DUCT, FAN TERMINAL UNITS, VARIABLE AIR VOLUME UNITS, AND DIFFUSERS.
2. DRAWBANDS SHALL BE EQUIVALENT TO PANDUIT PLT-H.

3 NTS FLEXIBLE DUCT CONNECTION DETAIL

2 NTS DRYER VENT BOX DETAIL

NOTES:

1. MAXIMUM SPACING BETWEEN HANGER LOCATIONS SHALL BE 5'-0".
2. STRAPS SHALL BE MINIMUM 1 1/2".
3. REFER TO SMACNA AND FLORIDA MECHANICAL CODE FOR ADDITIONAL REQUIREMENTS.
4. DUCTWORK SHALL BE SEALED IN MASTIC.

1 NTS FLEX DUCT HANGER DETAIL

ADAM J BARNEY LICENSE No. 69124 STATE OF FLORIDA PROFESSIONAL ENGINEER

Adam Barney
Jan 17 2018 3:06 PM

PERMIT REVIEW STAMP

ISSUE HISTORY

No.	Date	Description
1	1/18/2018	ISSUE FOR PERMIT

REVISION HISTORY

No.	Date	Description

FUGLEBERG KOCH
2555 Temple Trail, Winter Park, FL 32789 (407) 629-0595
www.fuglebergkoch.com BR569

CONSULTANT

Joseph, Lawrence & Co Consulting Engineers
1180 HARWOOD AVE. SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL: 321.972.4466
WWW.JLCENG.COM
CA NO. 28730

JLC 17.0137.00

Adam Joseph Barney
P.E. #:69124

SUMMER BAY APTS. II
LAKE COUNTY, FL

Drawn:	MJR/KCM
Checked:	BLS/AJB
Approval:	BLS/AJB
Date:	11/10/2017
Project #:	5389

DETAILS - MECHANICAL

M6.01

© 2013 These documents and their contents are the property of FUGLEBERG KOCH, PLLC - A20000103 and are issued only for the specific project noted on these drawings. Any reproductions, revisions, or modifications of these documents without the expressed written consent of Fugleberg Koch, PLLC is prohibited by law.