## REFERENCE NOTES: (X)

(1) MOUNT NEW CONDENSING UNITS TO NEW ROOF MOUNTED RAIL SYSTEM. REFER TO DETAIL ON SHEET M6.03.

(2) ROUTE REFRIGERANT LINES ABOVE ROOF AND THROUGH BUILDING SIDEWALL INTO TRUSS SPACE. REFER TO DETAIL #5 ON SHEET M6.03.

(3) SUPPORT REFRIGERANT PIPING ABOVE ROOF SURFACE PER ROOF SUPPORT DETAIL ON SHEET M6.03.

(4) INSTALL 66"x18" ELEVATOR SHAFT RELIEF VENTILATION LOUVER ON SHAFT SIDEWALL. RUSKIN MODEL #ELF6425DD OR EQUIVALENT. THE AREA OF THE VENT SHALL BE NOT BE LESS THAN 3-1/2% OF THE AREA OF THE HOISTWAY NOR LESS THAN 3 SQUARE FEET FOR EACH ELEVATOR CAR. PROVIDE MOTORIZED DAMPER CONNECTED TO BUILDING FIRE ALARM SYSTEM. DAMPER TO REMAIN NO LESS THAN 1/3 OPEN DURING NORMAL OPERATION AND FULLY OPEN DURING A FIRE/ALARM EVENT.

ADAM J BARNEY
LICENSE
No. 69124
STATE OF FLORIDA
PROFESSIONAL ENGINEER

Adam Barney
Jan 17 2018 3:02 PM
CoSign

H1 BUILDING TYPE 1 - ROOF - MECHANICAL
1/8" = 1'-0"

PERMIT REVIEW STAMP

### ISSUE HISTORY

| No. | Date | Description |
|---|---|---|
| 1 | 1/18/2018 | ISSUE FOR PERMIT |

### REVISION HISTORY

| No. | Date | Description |
|---|---|---|


FUGLEBERG KOCH
2555 Temple Trail, Winter Park, FL 32789 (407) 629-0595
www.fuglebergkoch.com BR569

CONSULTANT
Joseph, Lawrence & Co
Consulting Engineers
1180 HARWOOD AVE. SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL: 321.972.4466
WWW.JLCENG.COM
CA NO. 28730


JLC 17.0137.00

Adam Joseph Barney
P.E. #:69124

| | |
|---|---|
| SUMMER BAY APTS. II<br>LAKE COUNTY, FL | Drawn: MJR/KCM<br>Checked: BLS/AJB<br>Approval: BLS/AJB<br>Date: 11/10/2017<br>Project #: 5389 |

BUILDING TYPE 1 - ROOF - MECHANICAL

**M2.05**

© 2015 These drawings and files/ models are the property of FUGLEBERG KOCH, PLLC - LA26000120 and are issued only for the specific project noted on these drawings. Any reproductions, revisions, or modifications of these documents without the expressed written consent of Fugleberg Koch, PLLC is prohibited by law.