REFERENCE NOTES: (X)

1. SPRINKLER RISER LOCATED WITHIN WALL.
2. STANDPIPE LOCATED WITHIN WALL.
3. 2½" FROM STANDPIPE CONNECT TO 2½" FIRE HOSE VALVE LOCATED WITHIN RECESSED FIRE HOSE VALVE CABINET.
4. ALTHOUGH NOT SHOWN, PROVIDE SPRINKLER COVERAGE FOR CORRIDORS.
5. STANDPIPE UP.

ADAM J BARNEY
LICENSE
No. 69124
STATE OF FLORIDA
PROFESSIONAL ENGINEER

Adam Barney
Jan 17 2018 2:58 PM

H1 BUILDING TYPE 2 - LEVEL 2 - FIRE PROTECTION
1/8" = 1'-0"

PERMIT REVIEW STAMP

ISSUE HISTORY

No.	Date	Description
1	1/18/2018	ISSUE FOR PERMIT

REVISION HISTORY

No.	Date	Description

FUGLEBERG KOCH
2555 Temple Trail, Winter Park, FL 32789 (407) 629-0595
www.fuglebergkoch.com BR569

CONSULTANT
Joseph, Lawrence & Co
Consulting Engineers
1180 HARWOOD AVE. SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL: 321.972.4466
WWW.JLCENG.COM
CA NO. 28730

JLC 17.0137.00

Adam Joseph Barney
P.E. #:69124

SUMMER BAY APTS. II
LAKE COUNTY, FL

Drawn:	MJR/KCM
Checked:	BLS/AJB
Approval:	BLS/AJB
Date:	11/10/2017
Project #:	5389

BUILDING TYPE 2 - LEVEL 2
PLAN - FIRE PROT.

FP3.02

© 2015 These drawings and files contain and are the property of FUGLEBERG KOCH, P.L.C. - LB26001103 and are reserved only for the specific project noted on these drawings. Any reproductions, revisions, or modifications of these documents without the expressed written consent of Fugleberg Koch, P.L.C. is prohibited by law.