NOTE: EXTINGUISHER IN CABINET TO BE MIN. 4-A:60B:C-10 LB. VERIFY SIZE & TYPE WITH LOCAL FIRE OFFICIAL

D1 SEMI RECESSED FIRE EXTINGUISHER CABINET
1 1/2" = 1'-0"

NOTE:
SEE ELEVATIONS FOR LOCATION IN BUILDINGS

D3 FIRE SIGN DETAIL
1 1/2" = 1'-0"

LIFE SAFETY LEGEND

((XXX)) OCCUPANT LOAD

NOTES:
1. ALL UNIT DOOR CAPACITY - 180 PERSONS
2. 2. ALL EXIT DOOR COMMON AREA CAPACITY - 180 PERSONS
   EXCEPTION:GROUND FLOOR ENTRY LOBBY DOORS - 360 PERSONS
3. 36" WIDE ACCESSIBLE ROUTE REQUIRED PER FAIR HOUSING.
4. ALL DOORS ON ACCESSIBLE ROUTE TO HAVE A MINIMUM CLEARANCE OF 2'-8" (32").

EMERGENCY LIGHT
TRAVEL DISTANCE TO EXIT
F.E.C. — FIRE EXTINGUISHER VERIFY EXACT LOCATIONS AND TYPES WITH LOCAL FIRE OFFICIALS
20 MIN DOOR
45 MIN DOOR
60 MIN DOOR
90 MIN DOOR
XXX/XXX = XXX
OCCUPANCY SYMBOL
CAPACITY
SQUARE FEET PER PERSON
GROSS AREA (SQUARE FEET)
36" ACCESSIBLE ROUTE
REQUIRED 1 HOUR FIRE SEPARATION
REQUIRED 2 HOUR FIRE SEPARATION

PER SECTION FBC 717.
PROVIDE FIREBLOCKING AT 10'-0"
INTERVALS IN UL U341 WALLS

LIFE SAFETY NOTES:

1. SEE SHEET A0.30 THRU A0.36 FOR ALL U.L. ASSEMBLY DESIGN DESCRIPTIONS.
2. SEE SHEET A0.20 FOR ASSEMBLY SOUND RATINGS
3. PROVIDE RECESSED PORTABLE FIRE EXTINGUISHERS AS REQUIRED BY NFPA 10 STANDARDS FOR PORTABLE FIRE EXTINGUISHERS' 2014 EDITION. VERIFY EXACT LOCATION AND F.E. TYPE WITH FIRE OFFICIAL.
4. PROVIDE ONE 2-A: 10-B:C lb FIRE EXTINGUISHER PER UNIT. COORDINATE ACTUAL TYPE AND LOCATION PER FIRE DEPARTMENT REQUIREMENTS.
5. FIRE EXTINGUISHERS IN PUBLIC SPACES SHALL BE LOCATED WITHIN 75' TRAVEL DISTANCE.
6. COMBUSTIBLE MATERIALS SHALL NOT BE PLACED OR STORED ON BALCONIES PER THE FBC (5TH EDITION) AND NFPA 101 2014 EDITIONS.
7. EXTERIOR WALLS ARE NOT RATED FOR FIRE SEPARATION THEY ARE RATED FOR STRUCTURE ONLY.
8. SEE A0.02 FOR CODE DATA COMPLYING WITH THE FBC BUILDING CODE (5TH EDITION) BUILDING & INTERNATIONAL FIRE PREVENTION CODE (5TH EDITION)
9. ALL STAIRWAYS ARE TO CONFORM BUT NOT BE LIMITED TO NFPA 101 2014 EDITION SECTIONS 7.2.2.5.4 THROUGH 7.2.2.5.5.11.
10. ALL EXTERIOR & INTERIOR CONCRETE AND MASONRY BEARING WALLS SHALL HAVE (2) HR FIRE RATED RESISTANCE.

H1 BUILDING TYPE 2 - LS SECTION 1
1/8" = 1'-0"

PERMIT REVIEW STAMP

ISSUE HISTORY

No.	Date	Description
1	1/18/2018	ISSUE FOR PERMIT

REVISION HISTORY

No.	Date	Description

FUGLEBERG KOCH
2555 Temple Trail, Winter Park, FL 32789 (407) 629-0595
www.fuglebergkoch.com AA26002103

CONSULTANT

MICHAEL E. GOVE
FLORIDA LICENSE # AR94111

Digitally signed by Michael Gove
Date: 2018.01.18 13:59:40 -05'00'

STATE OF FLORIDA MICHAEL E. GOVE AR94111 REGISTERED ARCHITECT

SUMMER BAY APTS. II
LAKE COUNTY, FL

Drawn:	Author
Checked:	Checker
Approval:	Approver
Date:	Issue Date
Project #:	5389

LIFE SAFETY PLANS
SECTIONS - BLDG. TYPE 2

A0.17

PLOTTED: 1/22/2018 10:01:15 AM

© 2017 These documents and their contents are the property of FUGLEBERG KOCH ARCHITECTS, and are issued only for the specific project noted on these drawings. Any reproductions, revisions or modifications of these documents without the expressed written consent of Fugleberg Koch, is prohibited by law.