REFERENCE NOTES: (X)

(1) ROUTE EXHAUST DUCT FROM WALL MOUNTED EXHAUST FAN THROUGH TRUSS SPACE TO BUILDING SIDEWALL. TERMINATE DUCT AT EXTERIOR WALL CAP WITH BIRD SCREEN PER RISER ON SHEET M7.01. PRIME COAT AND PAINT WALL CAP TO MATCH BUILDING COLOR. SEE INDIVIDUAL UNIT PLANS FOR CONTINUATION.

(2) ROUTE DRYER EXHAUST DUCT THROUGH TRUSS SPACE TO BUILDING SIDEWALL. TERMINATE DUCT AT EXTERIOR WALL CAP PER RISER ON SHEET M7.01. PRIME COAT AND PAINT WALL CAP TO MATCH BUILDING COLOR. SEE INDIVIDUAL UNIT PLAN FOR CONTINUATION.

(3) ROUTE REFRIGERANT LINES WITHIN MECHANICAL CLOSET WALL UP TO ROOF MOUNTED CONDENSING UNIT. SEE PLUMBING PLANS FOR CONDENSATE LINE ROUTING.

(4) ROUTE OUTSIDE AIR DUCT FROM CORRIDOR AIR HANDLER ABOVE CEILING TO BUILDING SIDEWALL. TERMINATE WITH WALL CAP PER DETAIL ON SHEET M6.01. PRIME COAT AND PAINT WALL CAP TO MATCH BUILDING COLOR. PROVIDE MOTORIZED DAMPER IN VERTICAL SECTION OF OUTSIDE AIR DUCT IN MECHANICAL ROOM. OUTSIDE AIR INTAKE TO BE A MINIMUM OF 10'-0" FROM ALL EXHAUST OUTLETS.

(5) PROVIDE NEW FULLY DIGITAL 7 DAY PROGRAMMABLE TYPE THERMOSTAT WITH AUTO CHANGE OVER AND AUTO SET BACK. MOUNT THERMOSTAT 48" ABOVE FINISHED FLOOR. PROVIDE WITH CLEAR ACRYLIC LOCKING COVER.

ADAM J BARNEY
LICENSE
No. 69124
STATE OF FLORIDA
PROFESSIONAL ENGINEER

Adam Barney
Jan 17 2018 3:03 PM
CoSign

H1 BUILDING TYPE 2 - LEVEL 3 - MECHANICAL
1/8" = 1'-0"

PERMIT REVIEW STAMP

ISSUE HISTORY

No.	Date	Description
1	1/18/2018	ISSUE FOR PERMIT

REVISION HISTORY

No.	Date	Description

© 2013 These documents and their contents are the property of FUGLEBERG KOCH, P.L.C. - A20000120 and are issued only for the specific project noted on these drawings. Any reproductions, revisions, or modifications of these documents without the expressed written consent of Fugleberg Koch, P.L.C. is prohibited by law.

FUGLEBERG KOCH
2555 Temple Trail, Winter Park, FL 32789 (407) 629-0595
www.fuglebergkoch.com BR569

CONSULTANT
Joseph, Lawrence & Co
Consulting Engineers
1180 HARWOOD AVE. SUITE 3000
ALTAMONTE SPRINGS, FLORIDA 32714
TEL: 321.972.4466
WWW.JLCENG.COM
CA NO. 28730

JLC 17.0137.00

Adam Joseph Barney
P.E. #:69124

SUMMER BAY APTS. II
LAKE COUNTY, FL

Drawn:	MJR/KCM
Checked:	BLS/AJB
Approval:	BLS/AJB
Date:	11/10/2017
Project #:	5389

BUILDING TYPE 2 - LEVEL 3
PLAN - MECHANICAL

M3.03