

11/17/2021 4:14 PM  
PLX21074211.DWG

1. All drawings are to be coordinated with all site information by owner and contractor, and applicable codes.  
2. Contractor is to notify architect immediately of conditions or items varying from depicted information.  
3. Planworx Architecture, P.A. is not responsible for constructed variations from the information depicted.  
4. Planworx Architecture, P.A. will not assume any liability for expenses associated with errors and omissions on these drawings unless offset by verified construction savings as a result of planworx architecture, P.A. Design.  
5. Planworx Architecture, P.A. retains ownership of all of designs depicted and implied herein.  
6. Planworx Architecture, P.A. is not responsible for estimating, maintaining, or regulating construction costs associated with these plans.

### GENERAL NOTES - THIS SHEET

- SEE PANEL SCHEDULES FOR GFI PROTECTION OF SOME OUTLETS.
- FINAL CONNECTION TO ALL EQUIPMENT/FURNITURE BY E.C..

### TAGGED NOTES - THIS SHEET

- PROVIDE POWER & GFCI PROTECTION FOR POOL PUMPS. PROVIDE WITH NEMA 4X RATED DISCONNECT SWITCH. COORDINATE EXACT LOCATION & SPEC W/ G.C. & POOL CONTRACTOR BEFORE BEGINNING WORK. FINAL CONNECTION BY E.C..
- PROVIDE EMERGENCY "PUSH IN" POWER OFF SWITCH FOR POOL PUMPS. VERIFY LOCATION W/ LOCAL AHJ. WIRE TO SHUNT TRIP BREAKERS IN PANEL. SEE PANEL SCHEDULE.
- PROVIDE EMERGENCY PHONE RECEPTACLE. FIELD VERIFY LOCATION W/ LOCAL AHJ.
- PROVIDE POWER AND DATA FOR ELECTRONIC PARCEL BOXES. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH G.C..
- PROVIDE (2) 1" CONDUITS W/ CIRCUITS AS SHOWN TO POOL FOR POOL LIGHTS AND OTHER POOLSIDE EQUIPMENT. COORDINATE EXACT SIZE & LOCATIONS W/ G.C. & POOL CONTRACTOR. CIRCUIT TO BE CONTROLLED VIA TIME CLOCK.
- ATTIC EXHAUST FAN TO BE WIRED FOR CONTINUOUS OPERATION. COORDINATE W/ M.C..
- CORROSIVE ENVIRONMENT (NEC 680.14). SEE GENERAL NOTES SHEET E0.01.
- PROVIDE FIRE RATED PLYWOOD FOR TELE/DATA BOARD. PROVIDE #6 CU BONDING WIRE TO BUILDING GROUNDING SYSTEM.
- PROVIDE (3) 4" CONDUITS W/ PULL STRING TO TELE/DATA & CATV DEMARK POINTS FOR INCOMING SERVICE. COORDINATE W/ G.C. AND OWNER. METER AND WEATHERPROOF FUSED DISCONNECT.
- PROVIDE SERVICE RECEPTACLE AND SWITCHED LIGHT FIXTURE IN ATTIC ADJACENT TO HVAC EQUIPMENT. SWITCH TO BE PLACED AT ATTIC ACCESS.
- PROVIDE (2) 4" CONDUITS AND (1) 2" CONDUIT OUT FOR SITE DISTRIBUTION TO RESIDENTIAL BUILDINGS.
- PROVIDE (1) 2" CONDUIT AND (1) 1" CONDUIT TO ROOF FOR SATELLITE.
- PROVIDE DEDICATE POWER CIRCUIT FOR FITNESS EQUIPMENT.
- PROVIDE JUNCTION BOX AND CONDUIT FOR SECURITY CAMERA. COORDINATE EXACT BOX LOCATION AND CONDUIT TERMINATION POINTS WITH G.C. AND LOW VOLTAGE CONTRACTOR.
- PROVIDE CONDUIT AND POWER FOR CARD READER AND/OR DOOR LOCK. COORDINATE EXACT LOCATIONS AND DETAILS WITH G.C..

### TAGGED NOTES - THIS SHEET

- PROVIDE JUNCTION BOX AND CONDUIT FOR SPEAKER. COORDINATE EXACT BOX LOCATION AND CONDUIT TERMINATION POINTS WITH G.C. AND LOW VOLTAGE CONTRACTOR.
- PROVIDE JUNCTION BOX AND CONDUIT FOR A/V TOUCH PANEL CONTROLS. COORDINATE EXACT BOX LOCATION AND CONDUIT TERMINATION POINTS WITH G.C. AND LOW VOLTAGE CONTRACTOR.
- PROVIDE DATA OUTLET FOR WIRELESS ACCESS POINT. COORDINATE EXACT LOCATION AND REQUIREMENTS WITH LOW VOLTAGE CONTRACTOR.
- PROVIDE 2" CONDUIT UNDER SLAB AS SHOWN FOR FLOOR MOUNTED TELE/DATA OUTLETS. COORDINATE WITH LOW VOLTAGE CONTRACTOR.
- PROVIDE POWER RECEPTACLE FOR ACCESS CONTROL EQUIPMENT. RECEPTACLE TO BE EQUAL TO PASS & SEYMOUR SURGE PROTECTED ISOLATED GROUND DUPLEX. COORDINATE EXACT LOCATION AND REQUIREMENTS LOW VOLTAGE CONTRACTOR.
- PROVIDE POWER RECEPTACLE FOR TELE/DATA EQUIPMENT. RECEPTACLE TO BE EQUAL TO PASS & SEYMOUR SURGE PROTECTED ISOLATED GROUND DUPLEX. COORDINATE EXACT LOCATION AND REQUIREMENTS LOW VOLTAGE CONTRACTOR.
- PROVIDE POWER RECEPTACLE FOR A/V EQUIPMENT. RECEPTACLE TO BE EQUAL TO PASS & SEYMOUR SURGE PROTECTED ISOLATED GROUND DUPLEX. COORDINATE EXACT LOCATION AND REQUIREMENTS LOW VOLTAGE CONTRACTOR.
- PROVIDE QUAD POWER RECEPTACLE FOR SECURITY EQUIPMENT. RECEPTACLES TO BE EQUAL TO PASS & SEYMOUR SURGE PROTECTED ISOLATED GROUND DUPLEX. COORDINATE EXACT LOCATION AND REQUIREMENTS LOW VOLTAGE CONTRACTOR.
- PROVIDE FLOOR BOX WITH POWER, DATA, AND TV CONNECTION. COORDINATE EXACT FLOOR BOX SELECTION WITH OWNER.
- PROVIDE EMPTY 2" CONDUIT W/ PULL STRING TO POOL ACCESS GATES FOR ELECTRONIC ACCESS CONTROL DEVICE(S). COORDINATE WITH LOW VOLTAGE CONTRACTOR.

NOTE:  
E.C. TO VERIFY EXACT  
POOL EQUIPMENT  
REQUIREMENTS WITH  
EQUIPMENT SUPPLIER  
BEFORE BEGINNING  
WORK.

