

11/17/2021 4:13 PM  
PLX21074210.DWG

1. All drawings are to be coordinated with all site information by owner and contractor, and applicable codes. 3. Planworx Architecture, P.A. is not responsible for constructed variations from the information depicted. 5. Planworx Architecture, P.A. retains ownership of all of designs depicted and implied herein. 6. Planworx Architecture, P.A. is not responsible for estimating, maintaining, or regulating construction costs associated with these plans.  
2. Contractor is to notify architect immediately of conditions or items varying from depicted information. 4. Planworx Architecture, P.A. will not assume any liability for expenses associated with errors and omissions on these drawings unless offset by verified construction savings as a result of planworx architecture, P.A. Design.  
© Copyright 2021 - PLANWORX ARCHITECTURE, P.A. All rights reserved. Reproduction of this sheet, in whole or in part, is strictly prohibited. Plans may be used once by client. Unauthorized use strictly prohibited. PLANS NOT VALID FOR CONSTRUCTION W/O APPROPRIATE PROFESSIONAL SEALS.

- GENERAL NOTES - THIS SHEET**
1. ENSURE THAT ALL EXIT AND EMERGENCY LIGHTS ARE CONNECTED TO LOCAL NORMALLY ON LIGHTING CIRCUIT AND ARE WIRED UPSTREAM OF ALL SWITCHES, CONTACTORS, AND SIMILAR.
- TAGGED NOTES - THIS SHEET**
- ① LIGHTING CIRCUIT TO BE CONTROLLED VIA PHOTOCELL. SEE PANEL SCHEDULE.  
② POWER CIRCUIT FOR AREA LIGHT FIXTURE TO BE WIRED VIA AREA MOTION SENSOR, MOTION SENSOR TO BE UPSTREAM OF AREA SWITCHES. SEE DETAIL.  
③ MOTION SENSOR TO BE ON A 20 MIN TIMER  
④ FIXTURE TO BE WIRED AS A NIGHT LIGHT.  
⑤ SWITCH TO BE KEY OPERATED.

