



1. ALL CONDUIT AND WIRING TO BE CONCEALED WHEREVER POSSIBLE. ANY WIRING THAT MUST BE EXPOSED IS TO BE INSTALLED IN CONDUIT, INSTALLED IN A CLEAN & NEAT MANNER AND ROUTED IN SUCH A WAY AS TO MINIMIZE CONDUIT BEING VISIBLE.

- 1 PROVIDE SMOKE DETECTOR FOR ELEVATOR RECALL.
- 2 ADDRESSABLE RELAY MODULE FOR ALL DOOR HOLDER OPERATION IS LOCATED IN 1ST FLOOR TELECOM CLOSET. PROVIDE SMOKE DETECTOR ON BOTH SIDES OF DOORWAY.
- 3 PROVIDE HEAT AND SMOKE DETECTOR WITHIN 24" OF SPRINKLER HEAD. IF NO SPRINKLER HEAD PRESENT, OBTAIN AND PROVIDE CREDIT TO OWNER. COORDINATE W/ FIRE SPRINKLER CONTRACTOR. SPRINKLER HEAD SPECS, AND DETECTOR SPECS TO ENSURE DETECTOR WILL ACTIVATE PRIOR TO SPRINKLER HEAD.
- 4 PROVIDE BATTERY EXTENDER PANEL AND SMOKE DETECTOR.
- 5 PROVIDE CONNECTION TO ELEVATOR SYSTEM SHUNT TRIP. COORDINATE WITH E.C.,
- 6 FIRE ALARM SYSTEM TO BE INTERLOCKED WITH ELEVATOR CONTROLLER. COORDINATE REQUIREMENTS AND LOCATION W/ E.C. & ELEVATOR MFG.
- 7 PROVIDE SMOKE & HEAT DETECTORS FOR ELEVATOR RECALL FUNCTION. HEAT DETECTOR TO BE OMITTED IF NO SPRINKLER HEAD IS PRESENT. PROVIDE CREDIT TO OWNER.

SCALE: 3/32" = 1'-0"



5711 SIX FORKS ROAD, SUITE 100
RALEIGH NC 27609
website www.planworx.com

PERMIT SET



708 ST. MARYS ST
RALEIGH, NC 27605 LIC.#: P-0990
P:919-341-4247 F:919-890-3797
PLUMBING MECHANICAL ELECTRICAL

[illegible]

SHEET TITLE:

SHEET NUMBER:

FA1.13